

Delaware Aboveground Storage Tank Requirements For Tanks containing Diesel, Heating Fuel or Kerosene

	Registration	New Construction Fee	Annual Fee	Release Reporting & Remediation	Subject to Technical Regulations	Signage
ASTs > 250 gallons and ≤ 19,999 gallons*	X			X		
ASTs > 19,999 gallons and < 40,000 gallons	X			X		X
ASTs ≥ 40,000 gallons	X	\$3,750.00	\$750.00	X	X	X
ASTs > 250 gallons and < 1,100 gallons containing: <ul style="list-style-type: none"> ▪ Heating Fuel used on the premises where stored. ▪ Motor Fuel or Motor Oil used for non-commercial purposes. ▪ Ag/Farm substances including Petroleum products. 				X		
ASTs installed on a temporary basis, not to exceed six months.				X		
ASTs Regulated Pursuant to Title 29 Del. Code §8028. (Boiler Safety Program)				X		
ASTs regulated pursuant to Title 7, Del. Code Chapter 77. (Accidental Release Prevention Program)				X		

ASTs do NOT include: Flow through process tanks, Wastewater treatment works containment vessels, Transformers, Septic Tanks, Pipelines, Propane Tanks

*ASTs located on a farm have separate requirements.